



**GENERAL NOTES:**

1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
2. DELIVERY IS MADE BY CRANE-EQUIPPED TRUCKS
3. EXCAVATION MUST BE READY, SAFE AND ACCESSIBLE FOR UNLOADING FROM THE REAR OF THE TRUCK.
4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
6. MAXIMUM BURIAL DEPTH = 1 METRE IN FIRM SOIL AWAY FROM ANY VEHICULAR TRAFFIC
7. TUF-TITE SAFETY LIDS INSTALLED IN BOTH OPENINGS AS PER CSA-B66-21
8. TANK DESIGNED FOR A MAXIMUM FILL COVER DEPTH OF 1000MM, NO MINIMUM FILL COVER DEPTH, AND 12 kPa VEHICLE LOADING.



**MANUFACTURED:**  
LINDSAY, ON  
1-800-655-3430

**CONCRETE:** 35MPa  
**AIR CONTENT:** 5-8%  
**REINFORCEMENT:** STEEL TO CSA CAN  
A23.4-05 / A23.3. G30.18 Fy=400MPa

**WEIGHT:**  
Bottom - 15,941lbs / 7,246kg  
Top - 15,663lbs / 7,119kg  
**CSA APPROVED**      **AGINP**

**DRAWN BY:**  
PRASHAN

**14,000L SEPTIC TANK - TR**

**DATE:**  
JAN/2024

**WORKING CAPACITY:** 14,108L TO INVERT OF OUTLET  
**TOTAL CAPACITY:** 16,451L TO UNDERSIDE OF TOP