



- GENERAL NOTES:**
1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
  2. DELIVERY IS MADE BY CRANE-EQUIPPED TRUCKS
  3. EXCAVATION MUST BE READY FOR INSTALL
  4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
  5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
  6. TANK DESIGNED FOR A MAXIMUM FILL COVER DEPTH OF 1000mm. WITH 4.8 kPa LIVE LOAD, AND NO VEHICLE LOADING

\* AVAILABLE FOR TRAFFIC LOADING



**MANUFACTURED:**  
OTTAWA, ON  
1-800-655-3430

**CONCRETE TYPE:** SCC  
**CONCRETE:** 45MPa at 28 days / 6,500PSI  
**AIR ENTRAINMENT:** 5-8%  
**REINFORCEMENT:** STEEL TO CSA CAN  
A23.1 /A23.3 G30.18 Fy=400MPa

**WEIGHT:**  
BOTTOM - 17,712lbs / 8,050kg  
TOP - 17,571lbs / 7,989kg  
**CSA APPROVED**  
MEETS CAN/CSA-B66  
"AGINP"

**DRAWN BY:**  
N.CHAN  
**DATE:**  
FEB/2020

**18000 LITRES** **SINGLE CHAMBER**  
4,000 IMPERIAL GALLON

**WORKING CAPACITY:** 18658L TO INVERT OF INLET  
**TOTAL CAPACITY:** 20492L TO UNDERSIDE OF CHAMBER LID