



GENERAL NOTES:

1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
2. DELIVERY IS MADE BY CRANE-EQUIPPED TRUCKS
3. EXCAVATION MUST BE READY, SAFE AND ACCESSIBLE FOR UNLOADING FROM THE REAR OF THE TRUCK.
4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
6. MAXIMUM BURIAL DEPTH = 1 METRE IN FIRM SOIL AWAY FROM ANY VEHICULAR TRAFFIC
7. TUF-TITE SAFETY LIDS INSTALLED IN BOTH OPENINGS AS PER CSA-B66-21
8. TANK DESIGNED FOR A MAXIMUM FILL COVER DEPTH OF 1000MM, NO MINIMUM FILL COVER DEPTH, AND 12 kPa VEHICLE LOADING.



MANUFACTURED:
LINDSAY, ON
1-800-655-3430

CONCRETE: 35MPa
AIR CONTENT: 5-8%
REINFORCEMENT : STEEL TO CSA CAN
A23.4-05 / A23.3. G30.18 Fy=400MPa

WEIGHT:
Bottom - 19,907lbs / 9,030kg
Top - 19,429lbs / 8,813kg
CSA APPROVED AGINP

DRAWN BY:
PRASHAN

DATE:
JAN/2024

22,000L SEPTIC TANK - TR

WORKING CAPACITY: 22,897L TO INVERT OF OUTLET

TOTAL CAPACITY: 25,437L TO UNDERSIDE OF CHAMBER LID