



**GENERAL NOTES:**

1. CAS 603- CAST CLOSE AS POSSIBLE TO THE BOTTOM OF TANK
2. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
3. DELIVERY IS MADE BY CRANE-EQUIPPED TRUCKS
4. EXCAVATION MUST BE READY, SAFE AND ACCESSIBLE FOR UNLOADING FROM THE REAR OF THE TRUCK.
5. MIN OVERHEAD CLEARANCE OF 18FT IS REQUIRED
6. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT (I.E. SPREADER BAR)
6. MAXIMUM BURIAL DEPTH = 1 METRE IN FIRM SOIL AWAY FROM ANY VEHICULAR TRAFFIC

**\*2-NESTED FIRE WATER TANKS\***



**MANUFACTURED:**  
BROOKLIN, ON  
1-800-655-3430

**CONCRETE:** 35MPa/5000PSI  
**AIR ENTRAINMENT:** 6-8%  
MEETS CAN/CSA-B66-00  
**REINFORCEMENT:** STEEL TO CSA CAN  
A23.1 /A23.3 G30.18 Fy=400MPa

**WEIGHT:** 34,870lbs / 15,820kg  
**CPA CERTIFIED**

**DRAWN BY:**  
S.RIMLAND

**DATE:**  
JAN/2018

**22750 LITRES**  
**5000 IMPERIAL GALLON**

**TOTAL CAPACITY:** 25,853 LITRES TO UNDERSIDE OF CHAMBER LID  
PER TANK