



- GENERAL NOTES:**
1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
  2. CONTRACTOR TO ENSURE CRANE IS ON-SITE TO OFFLOAD AND SET TANK
  3. EXCAVATION MUST BE READY FOR INSTALL
  4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
  5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
  6. MAXIMUM BURIAL DEPTH = 1 METRE IN FIRM SOIL AWAY FROM ANY VEHICULAR TRAFFIC

TOP VIEW  
SCALE:1/50

SECTION A  
SCALE:1/50

SECTION B  
SCALE:1/50

**\*SINGLE FIRE WATER TANK\***

	<b>MANUFACTURED:</b> BROOKLIN, ON 1-800-655-3430	<b>CONCRETE:</b> 35MPa/5000PSI <b>AIR ENTRAINMENT:</b> 5-8% <b>REINFORCEMENT:</b> STEEL TO CSA CAN A23.1 /A23.3 G30.18 Fy=400MPa	<b>WEIGHT:</b> 41,623lbs / 18,919kg <b>BOTTOM:</b> 21,380lbs / 9,718kg <b>TOP:</b> 20,243lbs / 9,201kg CPA CERTIFIED MEETS CAN/CSA-B66 "AGINP"	<b>DRAWN BY:</b> N.CHAN	<b>30000 LITRES</b> <b>6600 IMPERIAL GALLON</b> <b>WORKING CAPACITY:</b> 31,503L TO INVERT OF INLET <b>TOTAL CAPACITY:</b> 33,926L TO UNDERSIDE OF CHAMBER LID
				<b>DATE:</b> FEB/2020	