



SECTION A  
SCALE: 1/60

SECTION B  
SCALE: 1/60

**\*2-LINKED FIRE WATER TANKS\***

**30000 LITRES**  
6600 IMPERIAL GALLON

WORKING CAPACITY: 30,283L INVERT OF INLET TO INVERT OF CAS 603 (PER TANK)  
TOTAL CAPACITY: 33,926L TO UNDERSIDE OF CHAMBER LID (PER TANK)

**GENERAL NOTES:**

1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
2. CONTRACTOR TO ENSURE CRANE IS ON-SITE TO OFFLOAD AND SET TANK
3. EXCAVATION MUST BE READY FOR INSTALL
4. MIN OVERHEAD CLEARANCE OF 18FT IS REQUIRED
5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
6. MAXIMUM BURIAL DEPTH = 1 METRE IN FIRM SOIL AWAY FROM ANY VEHICULAR TRAFFIC
7. MULTIPLE TANKS CAN BE CONFIGURED UPON REQUEST



MANUFACTURED BY:  
BROOKLIN, ON  
1-800-655-3430

CONCRETE: 35MPa/5000PSI  
AIR ENTRAINMENT: 6-8%  
REINFORCEMENT: STEEL TO CSA CAN  
A23.1 /A23.3 G30.18 Fy=400MPa

WEIGHT: 40,905lbs / 18,555kg  
BOTTOM: 20,662lbs / 9,373kg  
TOP: 20,243lbs / 9,182kg  
PER TANK  
CPA CERTIFIED  
MEETS CAN/CSA-B66

DRAWN BY:  
S.RIMLAND  
DATE:  
JAN/2019