



TOP VIEW
SCALE:1/60



SECTION B
SCALE:1/60



SECTION A
SCALE:1/60

1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
2. CONTRACTOR TO ENSURE CRANE IS ON-SITE TO OFFLOAD AND SET TANK
3. EXCAVATION MUST BE READY FOR INSTALL
4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
6. TANK DESIGNED FOR A MAXIMUM FILL COVER DEPTH OF 1000mm, WITH 4.8 kPa LIVE LOAD, AND NO VEHICLE LOADING

* AVAILABLE FOR TRAFFIC LOADING



MANUFACTURED:
OTTAWA, ON
1-800-655-3430

CONCRETE TYPE: SCC
CONCRETE: 45MPa at 28 days / 6,500PSI
AIR ENTRAINMENT: 5-8%
REINFORCEMENT: STEEL TO CSA CAN
A23.1 /A23.3 G30.18 Fy=400MPa

WEIGHT:
BOTTOM - 49,416lbs / 22,462kg
TOP - 50,845lbs / 23,111kg
CSA APPROVED
MEETS CAN/CSA-B66
"AGINP"

DRAWN BY:
N.CHAN

DATE:
FEB/2020

45500 LITRES SINGLE CHAMBER
10,000 IMPERIAL GALLON
WORKING CAPACITY: 44717L TO INVERT OF INLET
TOTAL CAPACITY: 48129L TO UNDERSIDE OF CHAMBER LID