



GENERAL NOTES:

1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
2. CONTRACTOR TO ENSURE CRANE IS ON-SITE TO OFFLOAD AND SET TANK
3. EXCAVATION MUST BE READY FOR INSTALL
4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
6. TANK DESIGNED FOR A MAXIMUM FILL COVER DEPTH OF 1000mm, NO MINIMUM FILL COVER DEPTH, AND 12 kPa VEHICLE LOADING
7. TUF-TITE SAFETY LIDS INSTALLED IN ALL OPENINGS AS PER CSA-B66-21



MANUFACTURED:
OTTAWA, ON
1-800-655-3430

CONCRETE: 40MPa / 5,800PSI
AIR ENTRAINMENT: 5-8%
REINFORCEMENT: MEETS G30.14-M1983

WEIGHT: 63,150lbs / 28,645kg (TOP)
81,625lbs / 37,025kg (BOTTOM)
MEETS CAN/CSA-B66
CSA APPROVED
"AGINP"

DRAWN BY:
JAY PATEL

DATE:
APRIL/2022

68500 LITRES **SINGLE CHAMBER**

WORKING CAPACITY: 70,735L TO INVERT OF INLET
TOTAL CAPACITY: 75,681L TO UNDERSIDE OF CHAMBER LID