



**GENERAL NOTES:**

1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
2. CONTRACTOR TO ENSURE CRANE IS ON-SITE TO OFFLOAD AND SET TANK
3. EXCAVATION MUST BE READY FOR INSTALL
4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
6. TANK DESIGNED FOR A MAXIMUM FILL COVER DEPTH OF 1000mm, NO MINIMUM FILL COVER DEPTH, AND 12 kPa VEHICLE LOADING
7. TUF-TITE SAFETY LIDS INSTALLED IN ALL OPENINGS AS PER CSA-B66-21



**MANUFACTURED:**  
OTTAWA, ON  
1-800-655-3430

**CONCRETE:** 40MPa / 5,800PSI  
**AIR ENTRAINMENT:** 5-8%  
**REINFORCEMENT:** STEEL TO CSA  
CAN A23.1 / A23.3 G30.18 Fy=400MPa

**WEIGHT:** 81,065lbs/36,770kg (TOP)  
81,625lbs/37,025kg (BOTTOM)  
CPA CERTIFIED  
MEETS CAN/CSA-B66  
"AGINP"

**DRAWN BY:**  
JAY PATEL

**DATE:**  
APRIL/2022

**84000 LITRES** **SINGLE CHAMBER**

**WORKING CAPACITY:** 86,752L TO INVERT OF INLET  
**TOTAL CAPACITY:** 91,606L TO UNDERSIDE OF CHAMBER LID