



- GENERAL NOTES:**
1. UNITS ARE SEALED WITH BUTYL TAPE AT THE JOINTS
  2. CONTRACTOR TO ENSURE CRANE IS ON-SITE TO OFFLOAD AND SET TANK
  3. EXCAVATION MUST BE READY FOR INSTALL
  4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
  5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT
  6. TANK DESIGNED FOR A MAXIMUM FILL COVER DEPTH OF 1000mm, NO MINIMUM FILL COVER DEPTH, AND 12 kPa VEHICLE LOADING.



MANUFACTURED:  
OTTAWA, ON  
1-800-655-3430

**CONCRETE:** 45MPa at 28 days / 6,500PSI **WEIGHT:** 81,065lbs/36,770kg (TOP)  
81,625lbs/37,025kg (BOTTOM)  
**AIR ENTRAINMENT:** 5-8%  
**REINFORCEMENT:** STEEL TO CSA  
CAN A23.1 /A23.3 G30.18 Fy=400MPa  
**CPA CERTIFIED**  
MEETS CAN/CSA-B66  
"AGINP"

**DRAWN BY:**  
N.CHAN  
**DATE:**  
FEB/2020

**90900 LITRES**  
20000 IMPERIAL GALLON  
**SINGLE CHAMBER**  
20,000 IMPERIAL GALLON / 90,900 LITRES