



GENERAL NOTES:

- 1. CABLE ENTRY OPENINGS 4-3/4" PVC SEALS
- 2. DELIVERY IS MADE BY CRANE-EQUIPPED TRUCKS
- 3. EXCAVATION MUST BE READY, SAFE AND ACCESSIBLE FOR UNLOADING FROM THE REAR OF THE TRUCK.
- 4. MIN OVERHEAD CLEARANCE OF 18FT IS REQUIRED
- 5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT (I.E. SPREADER BAR)
- * TYPICAL USE WOULD REQUIRE JW500 CAST IRON FRAME AND COVER





RIGHT VIEW SCALE:1/40



MANUFACTURED: BROOKLIN, ON 1-800-655-3430 CONCRETE: 35MPa / 5,000PSI AIR ENTRAINMENT: 6-8% REINFORCEMENT: STEEL TO CSA

CAN A23.1 / A23.3. G30.18 Fy=400MPa WEIGHT:

BCP115H20M -29,000lbs / 10,680kg PULLING EYES- 30,000lbs MAX TENSION EACH DRAWN BY: S.RIMLAND BCP115H20M

DATE: AUG/2017 PRECAST CONCRETE UTILITY MANHOLE

DESIGNED TO CL-625-ONT TRUCK LIVE LOADING AS PER CSA S6-14