



**GENERAL NOTES:**

1. CABLE ENTRY OPENINGS - 4-3/4" PVC SEALS
2. DELIVERY IS MADE BY CRANE-EQUIPPED TRUCKS
3. EXCAVATION MUST BE READY, SAFE AND ACCESSIBLE FOR UNLOADING FROM THE REAR OF THE TRUCK.
4. MIN OVERHEAD CLEARANCE OF 18FT (5.5 METRES) IS REQUIRED
5. ALL UNITS MUST BE HANDLED WITH PROPER LIFTING EQUIPMENT (I.E. SPREADER BAR)
6. AVAILABLE WITH SOLID LID FOR USE AS SPLICING CHAMBER
7. USE PROPER LIFTING EQUIPMENT, UNITS TO BE LIFTED BY LIFTING ANCHORS ONLY.

\* TYPICAL USE WOULD REQUIRE JW150 CAST IRON FRAME AND COVER (OPSD 401.01)



MANUFACTURED:  
BROOKLIN, ON  
1-800-655-3430

CONCRETE: 35MPa / 5,000PSI  
AIR ENTRAINMENT: 5-8%  
REINFORCEMENT : STEEL TO CSA CAN  
A23.1 / A23.3. G30.18 Fy=400MPa

WEIGHT:  
BCP36P- 970lbs / 440kg  
BCP36M LID- 295lbs / 134kg

DRAWN BY:  
N.CHAN

DATE:  
MAY/2020

**BCP36M**

PRECAST CONCRETE JUNCTION BOX.