



- GENERAL NOTES:**
1. ALL MATERIALS AND WORKMANSHIP CONFORM TO THE OBC2012
 2. STRUCTURE HAS BEEN DESIGNED IN ACCORDANCE WITH PART 4 OF THE OBC 2012
 3. THE STRUCTURE IS TO BE FOUNDATION ON FREE DRAINING NON-FROST SUSCEPTIBLE MATERIAL WITH A SOIL BEARING CAPACITY OF NO LESS THAN 30KPa
 4. CONCRETE ADHESIVE IS TO BE APPLIED TO THE JOINTS BETWEEN THE WALLS AND THE FLOOR/ROOF SLABS
 5. CONCRETE MATERIALS CONFORMS TO CSA A23.1
 6. REINFORCING STEEL CONFORMS TO CSA G30.18/ W.W.M. CONFORMS TO CSA G30.5

<p>BROOKLIN CONCRETE PRODUCTS</p>	<p>MANUFACTURED: BROOKLIN, ON 1-800-655-3430</p>	<p>CONCRETE: 35MPa / 5,000PSI</p> <p>AIR ENTRAINMENT: 6-8%</p> <p>REINFORCEMENT: STEEL TO CSA CAN A23.1 / A23.3. G30.18 Fy=400MPa</p>	<p>WEIGHT: FLOOR: 13,300lbs / 6,031kg</p> <p>BACK: 5,143lbs / 2,332kg</p> <p>2 SIDES: 9,930lbs / 4,503kg</p> <p>FRONT: 1,951lbs / 885kg</p> <p>ROOF: 13,300lbs / 6,031kg</p>	<p>DRAWN BY: S.RIMLAND</p>	<p>MODEL 200</p> <p>PRECAST CONCRETE UTILITY BUILDING</p> <p>TYPICAL USE: ABOVE GROUND ELECTRICAL ROOM</p>
		<p>DATE: AUG/2017</p>	<p>DATE: AUG/2017</p>		